



## Wall Panel

Conwed Panels are reliable, all-purpose acoustic solutions. Capable of multiple levels of durability, highly-customizable finishes, and mounting options, this product is suitable for schools, auditoriums, theaters, offices, and libraries: anywhere noise control is needed.

## Mineral Core

Mineral Core products are a tackable solution for environments that don't need as much noise absorption per square foot as other Conwed solutions, but still retain the sharp looks and finish of Conwed's fabric-wrapped products.

### Project architect responsibility

This is a general specification guide, intended to be used by experienced construction professionals, in conjunction with good construction practice and professional judgment. This guide is to aid in the creation of a complete building specification that is to be fully reviewed and edited by the architect of record (specifier). Sections of this guide should be included, edited, or omitted based on the requirements of a specific project. It is the responsibility of both the specifier and the purchaser to determine if a product or system is suitable for its intended use. Neither Conwed, nor any of its subsidiary or affiliated companies, assume any responsibility for the content of this specification guide relative to actual projects and specifically disclaim any and all liability for any errors or omissions in design, detail, structural capability, attachment details, shop drawings or other construction related details, whether based upon the information provided by Conwed or otherwise.

## SECTION 098413 – Fixed Sound-Absorptive Panels

### PART 1 - General

#### 1.1 — SUMMARY

A. Section includes:

Fixed sound-absorptive panels.

B. Related work:

The following items are not included in this Section and are specified under the designated Sections:

Section 092100 – PLASTER AND GYPSUM BOARD ASSEMBLIES for plaster and gypsum board walls and ceilings.

#### 1.2 — SUBMITTALS

A. Product data:

Submit manufacturer's product data including certified laboratory test reports and other data required to show compliance with these specifications.

B. Samples:

Submit 8 ¾ x 11 inch (for thicknesses up to 1 ½ inches) or 11 ½ x 11 ½ inch (for thicknesses larger than 1 ½ inches) samples of representative panel with factory detailed edge, and representative samples of mounting devices.

#### 1.3 — QUALITY ASSURANCE

A. Pre-installation conference:

Conduct conference at Project site to comply with requirements in Division 01.

#### 1.4 — DELIVERY, STORAGE, AND HANDLING

A. Project conditions:

Protect system components from excessive moisture in shipment, storage, and handling. Deliver in unopened bundles and store in a dry place with adequate air circulation. Do not deliver material to building until wet conditions such as concrete, plaster, paint, and adhesives have been completed and cured to a condition of equilibrium.



Disclaimer of liability: Technical information contained herein is furnished without charge or obligation and is given and accepted at recipient's sole risk. Conditions of use may vary and are beyond our control, and because of this Conwed makes no representation about, and is not responsible or liable for, the accuracy or reliability of data associated with particular uses of any product described herein.

## 1.5 — LIMITED WARRANTY

A. Limited warranty:

Provide manufacturer's standard limited 3-year warranty against manufacturing defects in material or workmanship.

## PART 2 - Products

### 2.1 — SOUND ABSORPTIVE PANELS:

A. Basis-of-Design: Conwed TK/AC Wall Panels.

1. **Construction:** Single core of dimensionally stable mineral fiber board.
2. **Substrate Density:** 16.8 pcf (½ inch thickness) and 22 pcf (⅝ inch thickness).
3. **Recycled content:** For fiberglass, 52 percent pre-consumer and 5 percent post-consumer recycled content.
4. **Core thickness:** ½ inch.
5. **Core thickness:** ⅝ inch.
6. **Width:** Max of 48 inches and custom.
7. **Length:** Max of 120 inches and custom.
8. **Corners:** Square.
9. **Edge profile:** Square.
10. **Fabric finish:** Manufacturer, pattern and color as selected; applied directly over face and edges of panels to provide full finished edge, fully tailored corners.
11. **Mounting type:** Impaling clips/perimeter adhesive.
12. **Mounting type:** Z-Clip plate to DW bracket or Z-Bar.
13. **Flammability (ASTM E 84):** Panel components shall have a Class "A" rating per ASTM E 84.
14. **Resistivity to heat or cold:** R-factor of 4.16 per inch of thickness.
15. **Acoustical performance:** Values below are for panels mounted in accordance with ASTM C 423 and vary by panel thickness and finish.
  - a. **Noise reduction coefficient (NRC)** for ½ inch thickness: —.
  - b. **Noise reduction coefficient (NRC)** for ⅝ inch thickness: 0.35.

## PART 3 - Execution

### 3.1 — INSTALLATION:

A. Verify wet work such as plastering and concrete is complete and dry. Verify building is enclosed and under standard occupancy conditions (60 - 85°F and not more than 70% relative humidity) prior to start of installation. Commencement of installation constitutes Installer's acceptance of surfaces and conditions.

B. Install products in accordance with manufacturer's written instructions and in proper relationship with adjacent construction, including the following:

1. For adhesive installation to substrate, provide temporary support to prevent panel slippage. Note: Impaling clips are designed to help hold panels in place until adhesive dries.

C. Touch-up, repair or replace damaged units until satisfactory results are obtained.

— End of Section —