



Wall Panel

Conwed Panels are reliable, all-purpose acoustic solutions. Capable of multiple levels of durability, highly-customizable finishes, and mounting options, this product is suitable for schools, auditoriums, theaters, offices, and libraries: anywhere noise control is needed.

Fabric | HI

Conwed's fabric-wrapped products, known as the Respond Series, are made with the leading textile manufacturers. With the addition of a 1/4" copolymer sheet hidden beneath the fabric, Fabric | HI products have high-impact resistance.

Product name history: Respond® HI was previously known as Rebound. This name change occurred on 03/16/2020.

Project architect responsibility

This is a general specification guide, intended to be used by experienced construction professionals, in conjunction with good construction practice and professional judgment. This guide is to aid in the creation of a complete building specification that is to be fully reviewed and edited by the architect of record (specifier). Sections of this guide should be included, edited, or omitted based on the requirements of a specific project. It is the responsibility of both the specifier and the purchaser to determine if a product or system is suitable for its intended use. Neither Conwed, nor any of its subsidiary or affiliated companies, assume any responsibility for the content of this specification guide relative to actual projects and specifically disclaim any and all liability for any errors or omissions in design, detail, structural capability, attachment details, shop drawings or other construction related details, whether based upon the information provided by Conwed or otherwise.

SECTION 098413 – Fixed Sound-Absorptive Panels

PART 1 - General

1.1 – SUMMARY

A. Section includes: Fixed sound-absorptive panels.

B. Related work: The following items are not included in this Section and are specified under the designated Sections: Section 092100 – PLASTER AND GYPSUM BOARD ASSEMBLIES for plaster and gypsum board walls and ceilings.

1.2 – SUBMITTALS

A. Product data: Submit manufacturer's product data including certified laboratory test reports and other data required to show compliance with these specifications.

B. Samples: Submit 8 3/4 x 11 inch (for thicknesses up to 1 1/2 inches) or 11 1/2 x 11 1/2 inch (for thicknesses larger than 1 1/2 inches) samples of representative panel with factory detailed edge, and representative samples of mounting devices.

1.3 – QUALITY ASSURANCE

A. Pre-installation conference: Conduct conference at Project site to comply with requirements in Division 01.

1.4 – DELIVERY, STORAGE, AND HANDLING

A. Project conditions: Protect system components from excessive moisture in shipment, storage, and handling. Deliver in unopened bundles and store in a dry place with adequate air circulation. Do not deliver material to building until wet conditions such as concrete, plaster, paint, and adhesives have been completed and cured to a condition of equilibrium.



Disclaimer of liability: Technical information contained herein is furnished without charge or obligation and is given and accepted at recipient's sole risk. Conditions of use may vary and are beyond our control, and because of this Conwed makes no representation about, and is not responsible or liable for, the accuracy or reliability of data associated with particular uses of any product described herein.



1.5 — LIMITED WARRANTY

A. Limited warranty:

Provide manufacturer's standard limited 3-year warranty against manufacturing defects in material or workmanship.

PART 2 - Products

2.1 — SOUND ABSORPTIVE PANELS:

A. Basis-of-Design: Conwed Respond® HI Ceiling Panels.

1. **Construction:** Composite core construction of dimensionally stable rigid fiberglass.
2. **Fiberglass Density:** 6 – 7 pcf.
3. **Core laminated** with a $\frac{3}{16}$ inch thick, resilient perforated copolymer face sheet.
4. **Recycled content:** For fiberglass, 52 percent pre-consumer and 5 percent post-consumer recycled content.
5. **Core thickness:** $\frac{9}{16}$ inch.
6. **Core thickness:** 1 $\frac{1}{16}$ inches.
7. **Core thickness:** 2 $\frac{1}{16}$ inches.
8. **Core thickness:** 3 $\frac{1}{16}$ inches.
9. **Core thickness:** 4 inches.
10. **Core thickness:** 4 $\frac{1}{16}$ inches.
11. **Width:** Max of 48 inches and custom.
12. **Length:** Max of 118 inches and custom.
13. **Corners:** Square.
14. **Edge profile:** Square.
15. **Edge profile:** Kerf/Square.
16. **Edge treatment:** Resin hardened.
17. **Edge treatment:** Aluminum for square edge only.
18. **Edge treatment:** High-pressure laminate for square edge only.
19. **Finish:** Manufacturer, type and color as selected.
20. **Mounting type:** Impaling clips/perimeter adhesive.
21. **Mounting type:** Concealed spline.
22. **Mounting type:** Z-Clips to Z-Bar.
23. **Mounting type:** Resin spots.
24. **Mounting type:** Z-Bar to Z-Bar.
25. **Mounting type:** Rotofast™ Snap-on Anchors.
26. **Mounting type:** Conwed Rotofast™ Z-Clips.
27. **Flammability (ASTM E 84):** Panel components shall have a Class "A" rating per ASTM E 84.
28. **Resistivity to heat or cold:** R-factor of 4.16 per inch of thickness.
29. **Acoustical performance:** Values below are for panels mounted in accordance with ASTM C 423 (Type D5 Mounting) and vary by panel thickness and finish.
 - a. **Noise reduction coefficient (NRC)** for $\frac{9}{16}$ inch thickness: 0.70.
 - b. **Noise reduction coefficient (NRC)** for 1 $\frac{1}{16}$ inch thickness: 0.85.
 - c. **Noise reduction coefficient (NRC)** for 2 $\frac{1}{16}$ inch thickness: 1.00.
 - d. **Noise reduction coefficient (NRC)** for 3 $\frac{1}{16}$ inch thickness: 1.05.
3. **Noise reduction coefficient (NRC)** for 4 $\frac{1}{16}$ inch thickness: 1.05.

PART 3 - Execution

3.1 — INSTALLATION:

A. Verify wet work such as plastering and concrete is complete and dry. Verify building is enclosed and under standard occupancy conditions (60 - 85°F and not more than 70% relative humidity) prior to start of installation. Commencement of installation constitutes Installer's acceptance of surfaces and conditions.

B. Install products in accordance with manufacturer's written instructions and in proper relationship with adjacent construction, including the following:

1. For adhesive installation to substrate, provide temporary support to prevent panel slippage. Note: Impaling clips are designed to help hold panels in place until adhesive dries.

C. Touch-up, repair or replace damaged units until satisfactory results are obtained.

– End of Section –



Disclaimer of liability: Technical information contained herein is furnished without charge or obligation and is given and accepted at recipient's sole risk. Conditions of use may vary and are beyond our control, and because of this Conwed makes no representation about, and is not responsible or liable for, the accuracy or reliability of data associated with particular uses of any product described herein.